




UNION TERRITORY OF JAMMU & KASHMIR
OFFICE OF THE BLOCK MEDICAL OFFICER AKHNOOR
Ph. 01924-252236, Fax: 01924-252998, E-Mail bmoakhnoor@gmail.com

Health & Sanitation Certificate

In reference to your office letter No.IDPS/H&S/2024-25 dated 04.02.2025, regarding Health & Sanitation Certificate in respect of International Delhi Public School Gura Brahmana Akhnoor, a two members medical team was constituted by the under signed vide order no. BMO/Akh/3751-52 dated 14.02.2025 by Sh. Mohmad Nadeem CHO & Sh. Bal krishan BHW of Block Akhnoor for inspection of health & sanitation of the school.

The Health & sanitation of the school has been found Satisfactory as reported by the team.


(Dr. Mohd. Saleem Khan)
Block Medical Officer
Akhnoor

No.:- BMO/AKH/: 4117-18

Dated: 10.03.2025

Copy to:-

- 1) Chief Medical Officer Jammu for information please.
- 2) Principal International Delhi Public School Gura Brahmana Akhnoor for information.
- 3) Office copy



**JAL SHAKTI (PHE) DEPARTMENT DIVISION AKHNOOR
WATER TESTING LABORATORY AKHNOOR
PINCODE : 181201**





Test Report

Report No:	25 (Chemical & Bacteria)			
Report Date:	19/Jun/2024			
Source Location:	International Delhi Public School Gurha Brahmana			
Source:	BORE WELL			
Condition:	Fit / Unfit			
Sr. No	Parameter	BIS Permissible limit(mg/l)	BIS Desirable limit(mg/l)	Test Results (mg/l)
1	Turbidity	5.00 (NTU)	1 (NTU)	0.55 N.T.U.
2	pH	8.5	6.5	7.8 pH
3	TDS	2000	500	302 mg/l
4	Total Alkalinity	600	200	230 mg/l
5	Chloride	1000	250	280 mg/l
6	Fluoride	1.5	1.0	0.4 mg/l
7	Nitrate	45	45	2.0 mg/l
8	Sulphate	400	200	230 mg/l
9	Calcium	200	75	105 mg/l
10	Total Hardness	600	200	260 mg/l
11	Iron	1.0	0.3	0.3 mg/l
12	Free Residual Chlorine	1.0 (At Source)	0.2	0.0 mg/l

Note:

- The test report and result relate to the specimen/ sample (s) of the material as delivered /received and tested in the laboratory.
- This test report shall not be reproduced in part, without the permission of this laboratory.
- Any correction invalidates this test reports.
- WQC lab always strives to provide accurate and reliable for all customers. However, it is not responsible for any financial/legal liability arising out of any errors or omissions. Refer to terms & Conditions of reports overleaf.


LAB ASSISTANT
Water Quality Control
Jal Shakti (PHE) Dept.


ASSISTANT EXECUTIVE ENGINEER
Water Quality Control
Jal Shakti (PHE) Dept.